

2010 Water Quality Report for the Village of Lawrence

This report covers the drinking water quality for the Village of Lawrence for the calendar year 2010. This information is a snapshot of the quality of the water that we provided to you in 2010. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.


Your water comes from three (3) groundwater wells. The three wells obtain groundwater from an aquifer that is characterized as "semi-confined." The State performed an assessment of our source water in 2003. Copies of the reports are available from the village's water department. Our wells were determined to have a moderately high susceptibility to contamination. The Village of Lawrence has an approved wellhead protection program.

- **Contaminants and their presence in water:** Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Hotline (800-426-4791)**.
- **Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).
- **Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water

comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

- Contaminants that may be present in source water include:
 - * **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
 - * **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
 - * **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
 - * **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
 - * **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.



Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2010 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2010. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **90th Percentile:** 90th Percentile is figured on 10 samples with 9 samples at or below the reported level.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **N/A:** Not applicable **ND:** not detectable at testing limit **ppb:** parts per billion or micrograms per liter
ppm: parts per million or milligrams per liter **pCi/l:** picocuries per liter (a measure of radioactivity).
- **Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Samples Collected at the Well house:

Regulated Chemical Contaminants	MCL	MCLG	Range of Detections	Our Water	Sample Date	Violation Yes / No	Typical Source of Contaminants
Arsenic (ppb)	10	10	4	4	09/22/10	No	Erosion of natural deposits
Barium (ppm)	2	2	0.12 – 0.12	0.12	09/22/10	No	Discharge of drilling wastes; Erosion of natural deposits
Fluoride (ppm)	4	4	0.13	0.13	09/22/10	No	Erosion of natural deposits
Gross Alpha (pCi/l)	15	0	4.6	4.6	01/08/08	No	Erosion of natural deposits
Radium (pCi/l)	5	0	0.0 – 0.3	0.3	01/08/08	No	Erosion of natural deposits

Unregulated Chemical Contaminants ²	Range of Detections	Our Water	Sample Date	Violation Yes / No	Typical Source of Contaminants
Sodium (ppm)	7	7	09/22/10	N/A	Erosion of natural deposits

² Unregulated contaminants are those for which EPA has not established drinking water standards. Monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.

Samples Collected in the Distribution System:

Contaminants Subject to an Action Level	Action Level, MCL, or MRDL	Range of Detections	Our Water	Sample Date	Violation Yes/No	Typical Source of Contaminants
Lead (ppb) ³	AL = 15	2.0 - 3.0	2.2	08/26/09	N/A	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm) ³	AL = 1.3	0.07 - 0.56	0.20	08/26/09	N/A	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Total Trihalomethanes (ppb)	MCL = 80	10	10	09/22/10	No	Disinfection byproduct
Free Chlorine Residual (ppm) ⁴	MRDL = 4.0 MRDLG = 4	0.09 – 0.39	0.26	Monthly	No	Disinfectant added to control microbes

³ 90 percent of the samples collected were at or below the level reported for our water.

Lead and Copper Violation column indicates samples exceeding the Action Level.

⁴ The MRDL and MRDLG are effective January 1, 2004. Compliance is based on an annual average.

If present, elevated levels of Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing.

The Village of Lawrence is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for thirty (30) seconds to two (2) minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

While your drinking water meets EPA’s standard for Arsenic, it does contain low levels of Arsenic. EPA’s standard balances the current understanding of Arsenic’s possible health effects against the costs of removing Arsenic from drinking water. EPA continues to research the health effects of low levels of Arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Monitoring and Reporting Requirements: The State and EPA require us to test our water on a regular basis to ensure its safety. We met all the monitoring and reporting requirements for 2010. We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at the Village Hall during normal business hours and can also be viewed by visiting the village website at www.lawrencemi.com. This report will not be sent to you.

We invite public participation in decisions that affect drinking water quality. The Village Council meets on the second (2nd) Tuesday of each month at 7:00pm at the Village Hall, Located at 157 North Paw Paw Street. For more information about your water, or the contents of this report, contact Ken Schaut at 269-674-8161. For more information about safe drinking water, visit the U.S. Environmental Protection Agency at www.epa.gov/safewater/.